



MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. GMSSS-16/2023/1473 Dated 20.01.2023
Issued to :- The Principal,
Govt. Model Sr. Sec. School,
Sector-16-D, Chandigarh.
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 21.01.2023
Client reference :- Sample collected by Laboratory Staff
Packing of sample :- Sample filled in P.P. and Glass Bottle.
Source of sample :- from School Tap of Govt. Model Sr. Sec. School,
Sector-16-D, Chandigarh.


S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.8
2.	pH	7.0-8.5	---	7.80
3.	Residual Chlorine	0.2 - 0.4	mg/L	0.2
4.	Total Alkalinity (as CaCO ₃)	200	-do-	84
5.	Total Hardness (as CaCO ₃)	200	-do-	68
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	120
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0


(Excellent)

Payment received vide Receipt No.01/2022-23/115951, dated 20.01.2023, Amount Rs.3300/-.

Note:- Water is fit for drinking.


Lab. No. MCPHL/23/ 398
Dated: - 24.01.2023


Chemist,
MCPH Laboratory,
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No. 1,
Chandigarh

Endst No. MCPHL/23/

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh with reference to your letter Endst. No. MOH/Supdt. Admn./2023/ 907 Dated 23.01.2023


Principal
Govt. Model Sr. Sec. School
Sector 16-D, Chandigarh.


Chemist
MCPH Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No. 1,
Chandigarh

Virtu-100a

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)


(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)

No. MOH/Supdt. Admn/NOC/2023/ 1587

Dated:- 08/2/2023

It is certified that an inspection team headed by Sh. Chander Mohan,
Chief Sanitary Inspector from Office of Medical Officer of Health,
Municipal Corporation Chandigarh inspected the Govt Model Senior Secondary
School, Sector 16-D, Chandigarh on 28.01.2023 and mentioned in inspection report
that the Govt Model Senior Secondary School, Sector 16-D, Chandigarh is
maintaining the hygienic sanitation condition in the premises as per the norms
prescribed by the Central/State/U.T Govt. This certificate is issued with the prior
approval of competent authority, Municipal Corporation Chandigarh.

The above Certificate is valid for a period of One-year w.e.f 24-01-2023
(i.e. Water Sampling Date).


Medical Officer of Health
Municipal Corporation
Chandigarh

To,

Govt Model Senior Secondary School,
Sector 16-D,
Chandigarh